

Amendment

This is to notify all concerned that, as per decision of pre bid meeting held on 11.06.14 with several stakeholders relating to Request for Proposal (RFP) for the Intruder Alarm System / Digital Protection (Centralized Monitoring) System for the safety of vault room of the Branches of IBBL the following amendments have been approved in the mentioned RFP by the competent authority of the bank. All concerned are requested to follow/include/treat the amendments as an integral part for the same.

SL. No.	Topic	Amendment
1.	Page – 4, section – 1.2 (Work completion time)	Project completion time will remain unchanged but the number of Branches among the phases may be relaxed (1 st phase, 2 nd phase & 3 rd phase).
2.	Page – 5, section – 1.7 (Deadline of bid)	Submission date will be extended up to 24.06.2014 at 3.00PM.
3.	Page – 13, section – 3.2.1	Local recording may be taken through Wi-Fi or Ethernet media.
4.	Page – 14, point – 4 (Noise sensor)	Optional but preferable.
5.	Vibration Sensor	Minimum 01 unit of vibration sensor has to set in each wall (inner side) of the vault room.
6.	Set position of the security devices	All the concerned devices for vault security will be set at the vault room.
7.	Focus of the camera	The camera will be focused upon the door of vault room (inner side).
8.	Join venture affiliation	Foreign affiliation / Join venture party (JVP) are allowed complying the regulations of the country (related documents must be submitted).

As per amendments made by the authority the Time schedule of Tender's selling /dropping is replaced by the following:

SL. No	Tender to be sold	Tender to be submitted/dropped	Remarks
01	18.06.2014 up to 3.00 PM.	18.06.2014 up to 3.00 PM.	As per previous notice.
02	24.06.2014 up to 3.00 PM	24.06.2014 up to 3.00 PM.	As per present notice.

Senior Vice President (ED)